

CERTIFICATE OF COMPLIANCE

Certificate Number A-EX29043
Report Reference EX29043-20230425
Date 2023-April-27

Issued to: PIETRA S.P.A
Via Orzinuovi 2
Via Orzinuovi 2
Brescia BS 25125 IT

This is to certify that representative samples of METALLIC SPRINKLER PIPE
See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 852 Metallic Sprinkler Pipe for Fire Protection Service

Additional Information: See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.

Deborah Jennings-Conner

Deborah Jennings-Conner, VP Regulatory Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number A-EX29043
Report Reference EX29043-20230425
Date 2023-April-27

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Metallic Sprinkler Pipe

Steel sprinkler pipe for wet, dry, preaction and deluge type sprinkler systems with unthreaded ends intended to be joined by welding or Listed Rubber Gasketed Fittings when installed in accordance with the fitting manufacturer's specifications.

Schedule STD steel pipe in the 1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 3-1/2, 4, 5, 6, 8, 10, and 12 inch sizes in accordance with ASTM A53, Type S, Grade B.

Deborah Jennings-Conner

Deborah Jennings-Conner, VP Regulatory Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

